



Innovations in Nuclear Technology 2012

Brazil: Challenges and Opportunities

December 10th and 11th 2012 – São Paulo - SP

ELETRONUCLEAR

Fukushima Disaster Response Plan




presented by Paulo Carneiro

Fukushima Daiichi Accident

“Events at Fukushima revealed well known and recurrent issues”


- faulty design (underestimation of tsunami risks; design criteria for tsunamis 5,7m and inadequate plant layout);



- insufficient backup systems;
- improper decision making process (“human error”);
- inadequate contingency plans.

*Communication from the
Commission to the Council
and the European
Parliament (Oct.4th 2012)*


COMPANY ORGANIZATION TO RESPOND TO FUKUSHIMA



Full Integration to Nuclear Industry Initiatives



1st Document - Preliminary Report


 RELATÓRIO		CLASSE	Nº
ASSUNTO/MOTIVO		PÁGINA	
AVALIAÇÃO DAS LIÇÕES APRENDIDAS COM O ACIDENTE NAS USINAS DA CENTRAL DE FUKUSHIMA NO JAPÃO E SUAS IMPLICAÇÕES SOBRE AS UNIDADES DA CNAEA		1 / 65	
		LOCAL/DATA	
		Rio, 19.07.2011	
		REDATOR	
REFERÊNCIA		Paulo Vieira e outros	
		U.O./TEL.	
		DT / 7263	
		CÓDIGO ARQUIVO	
		DT-006/11	
SU	<i>Evaluation of Lessons Learned from Fukushima Accident and Implications for Angra Nuclear Power Station</i>		EMENTE, NO SUMÁRIO: (DURAÇÃO)
OBJETIVO		Para ser providenciado Para conhecimento prazos	
<p>Este Relatório tem por objetivo avaliar as lições aprendidas com o acidente de Fukushima Daiichi no Japão.</p> <p>O Relatório será encaminhado para o atendimento ao Ofício 082/11 – ELETRONUCLEAR proceda a análise da CNAEA considerando a ocorrência.</p> <p>O anexo apresentado ao final do relatório é considerado pela Eletronuclear</p>			
<ul style="list-style-type: none">• Plant Comparison Angra x Fukushima;• Design Criteria for Protection Against External Events;• Preliminary Evaluation of Plant Behavior for Station Blackout and Loss of Ultimate Heat Sink;• Measures for Mitigation of Consequences from Severe Accidents			

Submitted to
Brazilian
Nuclear
Authority –
CNEN in
August, 2011

2nd Document – Fukushima Response Plan

(submitted to CNEN in December 2011)

(revision 1 submitted to CNEN in September 2012)

 Eletrobras Eletronuclear	RELATÓRIO	CLASSE 3	Nº P-001/11		
ASSUNTO/MOTIVO ELETROBRAS ELETRONUCLEAR PLANO DE RESPOSTA A FUKUSHIMA (aprovado pela RDE nº 1054.001/11 de 30.11.2011)		PÁGINA 1 / 44			
		LOCAL/DATA Rio, 28.11.2011			
		REDATOR Paulo Carneiro			
		U.O./TEL. DT / 7053			
REFERÊNCIA CNAAB		CÓDIGO ARQUIVO P-001/11			
Sumário A elaboração do PLANO DE RESPOSTA A FUKUSHIMA apresentado neste Relatório foi determinada pela Diretoria Executiva, como uma das atribuições do Comitê Gerencial de Resposta a Fukushima, instituído pela CGE nº 038/11 de 20/09/2011.		Nº DE PÁGINAS 44	ANEXOS 3	(NOS RELATÓRIOS DE REUNIÃO INDICAR, INICIALMENTE, NO SUMÁRIO: LOCAL, DATA, COORDENADOR, PARTICIPANTES E DURAÇÃO)	Para ser providenciado Para conhecimento prazos

**58 initiatives
(studies and
projects)**

**Performance of
Stress Tests**

**Around
US\$ 200 million to
be applied from
2011 to 2016**

**High priority
inside the
organization**

Plan General Structure

Main Evaluation Areas of FUKUSHIMA RESPONSE PLAN

PE

PROTECTION FROM RISK EVENTS

15 initiatives

Focus:

Protection from events with the potential to induce multiple failures in safety systems

Objective:

Assure that safety systems are preserved in case of extreme conditions associated with external or internal events, beyond the design basis.

RF

COOLING CAPABILITY

32 initiatives

Focus:

Reactor and Spent Fuel Pool cooling capability in case of beyond design basis accidents

Objective:

Provide alternative possibilities for reactor and fuel pool cooling, for conditions beyond design basis

CR

MITIGATION OF RADIOLOGICAL CONSEQUENCES

9 initiatives

Focus:

Mitigation of radiological consequences in case of severe accidents

Objective:

Provide means to minimize the risk of losing containment integrity and releases of radioactivity materials to the environment. Improvements on Emergency Planning

Time evolution of accidents – Defense in Depth

Main Evaluation Areas

PROTECTION FROM RISK EVENTS

Earthquakes

Rains

Landslides

Tidal Waves

Tornadoes and Hurricanes

Plant Internal Events

COOLING CAPABILITY

Reactor Cooling Through Steam Generators

Direct Reactor Cooling

Spent Fuel Pool Cooling

Emergency Power Supply

Water Supply

Procedures for Severe Accident Management

MITIGATION OF RADIOLOGICAL CONSEQUENCES

Containment Integrity

Post Accident Instrumentation

Support to Emergency Planning

Stress Tests

General Nuclear Industry Approach for Safety Reevaluation

Stress Tests



assure reactor and
spent fuel pool cooling
under extreme severe
conditions

- what are the main **risk events** threatening the plant?
- are the **plant design criteria** for consideration of such risk events suitable, considering the plant site characteristics?
- are such plant design criteria **properly applied** in the design and construction?
- what are the **safety margins** in the design for coping with such risk events?

PE

- what additional resources are available to cope with the **failure of the plant safety systems**?

RF

- what are the resources and infrastructure for **mitigating the consequences of a severe accident** (protection of plant workers, public and environment)?

CR



Initiatives of ETN Fukushima Response Plan

Stress Test according to WENRA Specification and Process

Utility Report → Regulator Report → Peer Reviews



Iberoamerican Forum



Other National Investigation Programs



“Canadian
Stress Test”
(18 reactors)

NRC Task Force
Safety Reevaluation
(104 reactors)



Safety Evaluation Program
(16 reactors)



Safety Reassessment
Program
(2 reactors)

Safety
Review
(23 reactors)


Safety
Assessment
Lessons Learned
(50 reactors)



Investigation on Limit Conditions for Plant Safety

Basic Assumptions

- loss of all AC-power supply (SBO)
- loss of ultimate heat sink (LUHS)
- no external support to the nuclear power station within 72 hours



To be assured:

- capability for reactor cooldown and for long term cooling;
- capability for long term spent fuel pool cooling;

taking into consideration:

- full power operation;
- plant outage with full core unloaded


Main Recommendations from Stress Tests

- reevaluation of **seismic hazard** (probabilistic assessment and evaluation of safety margins);
- reevaluation of **flooding risks** (dam rupture, river overflow, heavy rains);
- reevaluation of risks associated with **tsunami and meteorological phenomena** at the oceans;
- provision of **alternative emergency power supply sources**;
- **mobile equipment** for emergency power supply and SG feeding;
- improvement of **spent fuel pool instrumentation**;
- hardened systems and equipment for **containment protection** (H₂ passive recombiners and containment venting);
- implementation of specific **procedures for managing severe accidents** (EDMGs e SAMGs)
- implementation of **emergency response teams**;
- improvement of **emergency centers**;
- improvement of **Emergency Plans**;

Performance of Stress Tests for Angra 1 and 2 (and later on for Angra 3)




According to specification
issued by Iberoamerican
Forum of Regulatory
Bodies, Nuclear and
Radiological (request from
CNEN in January 2012)



**compliance with
WENRA
Specification for
Stress Tests**



3rd Document – Stress Test Report – Angra 1 and 2


 Eletrobras Eletronuclear	RELATÓRIO	CLASSE 3	Nº DT-006/12
RELATÓRIO DE AVALIAÇÃO DE RESISTÊNCIA DAS UNIDADES DA CENTRAL NUCLEAR ALMIRANTE ÁLVARO ALBERTO PARA AS CONDIÇÕES DO ACIDENTE DE FUKUSHIMA ("STRESS TEST")		PÁGINA 1 / 90	
		LOCAL/DATE Rio, 29.03.2012	
		REDATOR Paulo Carneiro (coordenador)	
		U.O./TEL. DT / 7053	
REFERÊNCIA CNAAA	CÓDIGO ARQUIVO DT-006/12		
Sumário	Nº DE PÁGINAS 90	ANEXOS 3	(NOS RELATÓRIOS DE REUNIÃO INDICAR, INICIALMENTE, NO SUMÁRIO: LOCAL, DATA, COORDENADOR, PARTICIPANTES E DURAÇÃO)
Este relatório tem por objetivo avaliar a resistência das unidades 1 e 2 da Central Nuclear Almirante Álvaro Alberto para condições extremas além das bases de projeto, à luz das lições aprendidas com o acidente ocorrido em 11 de março de 2011 na Central de Fukushima Daiichi no Japão.			Para ser providenciado Para conhecimento prazos

Submitted to Brazilian Nuclear Authority in April 2nd, 2012

Protection Against Severe External Events

Three main areas of evaluation:

- plant capacity to withstand external events of large magnitude preserving the operability of essential safety systems for safe plant shutdown;




- alternatives

in case of
impacts of
large magnitu

- countermeasures
consequences
be avoided

- what are the main **risk events** threatening the plant?
- are the **plant design criteria** for consideration of such risk events suitable, considering the plant site characteristics?
- are such plant design criteria **properly applied** in the plant design and construction?
- what are the **safety margins** in the design for coping with the **uncertainties** associated with such risk events?



special attention to “clift edge” effects !!!

Tsunamis excluded




No possibility of Tsunamis at the Brazilian coast confirmed by independent studies carried out in 2005

Maximum conceivable earthquake magnitude at ocean: 7.0

Brazilian coast far from the boundaries of tectonic plates;

Tectonic plates in front of Brazilian coast with diverging movement instead of converging (no subduction zone)

NPP located in a low seismicity region



More relevant earthquakes in Brazil within 200 miles from the plant

1967 - Cunha, SP - 4.1 m_b (50km)

- basis for seismic design;
- max. peak ground acceleration 0,067g
- 0,1g considered for the design

2008 – São Vicente – 5.2 m_b (250km)

- peak ground acceleration at site 0,002g

- maximum ground peak acceleration confirmed by probabilistic assessment (probability less than 10^{-4} /year);
- updating of seismic and geological data (with support of PETROBRAS) ←
- evaluation of safety margins according to EPRI methodology under preparation; ←
- expectation of adequate safety margins considering results for similar

NPP installed in a region of protected sea water



**Plant construction level 5,15m
above sea water level, jetty
protection from sea waves**

sea side

0 CNG

**PROTECTION
JETTY**
(protection from
waves up to 4.40m
high over maximum
sea water level of
+1.50m)

plant construction level

+ 8,00m to + 8,50m

access level do
safety buildings

+ 5.15m + 5.60m

0 CNG

**Angra
1 e 2**


plant side

**Planned reevaluation of
wave heights considering
meteorological adverse
conditions**



**+1,197m maximum according to
updated reevaluation**


Specific Angra Site Hazard – Heavy Rains



Simulation considering more conservative channel obstruction scenarios with continued operation of circulating water pumps:

- definition of safety margin (consideration of flooding above +5.60 grade);
- possibility of additional measures under evaluation to enlarge safety margins (Angra 2 emergency feedwater building already designed for +8,15)

Flooding calculated considering rain fall of 10,000 years recurrence time (311 mm/hr)




Specific Angra Site Hazard – Risk of Landslides

slope stabilization works and
slopes monitoring under
independent assessment

study of consequences of
total slope rupture

slope stabilization near to safety
buildings considering seismic
requirements




Stress Test Report Angra 1 and 2

Three main areas of evaluation:

- plant capacity to withstand external events of large magnitude preserving the operability of essential safety systems for safe plant shutdown;
- alternative means to assure safe plant shutdown in case the operability of plant safety systems is impacted by external events of large magnitude;

• co
cor
be

- conditions for long term reactor and fuel pool cooling;
- consideration of plant power operation and refueling;
- consideration of station blackout (SBO) and loss of ultimate heat sink (LUHS)





Evaluation of Station Blackout Scenarios (SBO)

Favorable power supply conditions in Angra 1 and Angra 2


Improvements under evaluation for Angra 1:

- ✓ increased flooding protection;
- ✓ alternative diesel cooling chain.



normal design condition
(2 diesel groups per reactor, as Fukushima)

special design conditions for Angra 1 and 2
(12 diesel groups for 2 reactors !!!)



Evaluation of Station Blackout Scenarios (SBO)

Other favorable Angra conditions to face SBO

- both units are engineered with mechanical driven pumps for feeding the steam generators (power supply not necessary);
- large amounts of stored fuel available for long term operation of diesel generators.

Initiatives for increasing reliability of external power supply (under evaluation)



small
hydropower
plant at
Mambucaba
River

provisions for “house loading
operation”;

dedicated transmission lines
from Santa Cruz Power Plant

Evaluation of Loss of Heat Sink Condition

Favorable Angra conditions:

- water intake structures in area of **protected sea water** (Ilha Grande Bay);
- **water intake structures protected by jetty 8,0m** high above average seawater level;
- **very low probability of water intake blockage** to the extent of impairing minimum flow for residual heat removal (required flow < 3% full power flow);
- **water availability at site** enough for long term cooling through steam generators (about 30 hours SG feeding without tank refilling);
- possibility of **feeding steam generators by fully passive means** (fire fighting system, water reservoir of 5400 m³ at 110m height; second seismic proof reservoir under evaluation);

Additional Resources for Facing SBO and LUHS

For each unit, installation in 2013:


- mobile diesel generator for supplying essential systems for plant safe shutdown (480V-1800kVA);
- portable diesel generator for batterie charging (480V-450kVA);
- mobile water pumps as an alternative mean for feeding the steam generators (75m head and 27kg/s);
- mobile water pumps for refilling water reservoirs and pools (20m head and 20kg/s);
- mobile air compressor for Angra 1 as alternative mean for remote actuation of main steam and feedwater valves



Stress Test Report Angra 1 and 2

Three main areas of evaluation:

- plant capacity to withstand external events of large magnitude preserving the operability of essential safety systems for safe plant shutdown;
- alternative means to assure safe plant shutdown in case the operability of plant safety systems is impacted by external events of large magnitude;
- countermeasures to mitigate radiological consequences in case a severe accident can not be avoided.



Mitigation of Consequences

Equipment to protect containment integrity:

- filtered containment venting and H₂ passive catalytic recombiners for Angra 1 (Westinghouse) and Angra 2 (AREVA).



Severe Accident Management:


- Angra 1: SAMGs already available, staff training to be started (Westinghouse);
- Angra 2: SAMGs under preparation (joint project AREVA and ELETRONUCLEAR).



Initiatives to Improve Emergency Planning

- implementation of **tracks** as alternative evacuation route in case of road obstruction;
- construction and enlargement of **wharfs** in the vicinity of the nuclear power station as alternative mean for personnel and equipment transportation by sea (design for Frade and Praia Vermelha concluded);
- improvement of **integration between Emergency Centers** (focus on communication systems);
- improvement of **radiological protection** resources for facing severe accidents (“Expert Group on Severe Accident Management” do ISOE/NEA- OCDE/IAEA).

Revision of Fukushima Response Plan



Implementation of Safety Improvements

PROTECTION FROM RISK EVENTS	COOLING CAPABILITY	MITIGATION OF RADIOLOGICAL CONSEQUENCES
Earthquakes	Reactor Cooling Through Steam Generators	Containment Integrity
Rains	Direct Reactor Cooling	Post Accident Instrumentation
Landslides	Spent Fuel Pool Cooling	Support to Emergency Planning
Tidal Waves	Emergency Power Supply	
Tornadoes and Hurricanes	Water Supply	
Plant Internal Events	Procedures for Severe Accident Management	Tier 1 – 2013/2014
		Tier 2 – 2014/2015
		Tier 3 – 2015/2016



THANKS FOR THE ATTENTION !

Innovations in Nuclear Technology 2012
Brazil: Challenges and Opportunities
December 10th and 11th 2012 – São Paulo - SP